



AQUA PRO-TECH LABORATORIES
 Certified Environmental Testing

Client: Teaneck Community Charter School
 563 Chestnut Ave
 Teaneck, NJ

APL Order ID Number: 6060807
 Collected : 06/27/2016 8:45
 Received: 06/27/2016

Contact:
 Report Date: 07/05/2016 11:18

Client Project: Teaneck Community Charter School
 Customer Service Rep: Tony Tudda

Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
6060807-01	Drinking Water	FB						
Total Metals								
Lead	EPA 200.8	7/1/16 13:23	7/1/16 13:23	< 0.00200			0.00200	mg/L
6060807-02	Drinking Water	Nurse's Office Sink						
Total Metals								
Lead	EPA 200.8	7/1/16 13:27	7/1/16 13:27	0.00204			0.00200	mg/L
6060807-03	Drinking Water	Kitchen Sink						
Total Metals								
Lead	EPA 200.8	7/1/16 13:31	7/1/16 13:31	< 0.00200			0.00200	mg/L
6060807-04	Drinking Water	1st Floor Ftn Near Rm 125						
Total Metals								
Lead	EPA 200.8	7/1/16 13:36	7/1/16 13:36	< 0.00200			0.00200	mg/L
6060807-05	Drinking Water	Kindergarten (118) Sink						
Total Metals								
Lead	EPA 200.8	7/1/16 13:40	7/1/16 13:40	0.00239			0.00200	mg/L
6060807-06	Drinking Water	2nd Floor Ftn Left						
Total Metals								
Lead	EPA 200.8	7/1/16 13:44	7/1/16 13:44	< 0.00200			0.00200	mg/L

Brian Wood
 Laboratory Director



Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
6060807-07	Drinking Water	2nd Floor Ftn Right						
Total Metals								
Lead	EPA 200.8	7/1/16 13:49	7/1/16 13:49	< 0.00200			0.00200	mg/L
6060807-08	Drinking Water	Teacher's Lounge						
Total Metals								
Lead	EPA 200.8	7/1/16 13:53	7/1/16 13:53	< 0.00200			0.00200	mg/L
6060807-09	Drinking Water	Rm 218 Grades 6 & 7 Sink						
Total Metals								
Lead	EPA 200.8	7/1/16 13:58	7/1/16 13:58	0.00221			0.00200	mg/L

FootNotes

RL - Reporting limit
 MDL - Minimum detection limit
 U or ND - Indicates compound analyzed for but not detected
 J - Indicates estimated value

B - Indicates compound found in associated blank
 E - Concentration exceeds highest calibration standard
 D - Indicates result is based on a dilution
 P - Greater than 25% diff. between 2 GC columns.

Brian Wood
 Laboratory Director

